

DEPARTMENT OF CIVIL AVIATION
SIR SEEWOOSAGUR RAMGOOLAM INTERNATIONAL AIRPORT
PLAINE MAGNIEN
REPUBLIC OF MAURITIUS
Tel: (230) 603 2000
Fax: (230) 637 3164
Email: civil-aviation@govmu.org

ADDENDUM No. 2

Dear All

**Construction of Permit Office at SSR International Airport for the
Department of Civil Aviation**

CAV/QUO: No.11 of 2025-26

With reference to the abovementioned project, please find hereunder reply to the query:

Query

Quote

We kindly request you to Clarify the following Discrepancies between BOQ and Drawings:-

Bidding Doc Vol II, Bill No 7- Item 18,describes for "**60mm thick Premix Asphalt of grade 0/14**" whereas Structural Engineers Drawing shows "30mm thick with two different grades"-**PLEASE CLARIFY**

Unquote

Answer

Our consultant has confirmed that the TARMAC thickness shall be **60mm** as detailed in the **BILL OF QUANTITIES** and Base-Course & Wearing-Course to be merged into in a single layer of 0/14 Premix Asphalt as depicted in the attached Annex.


A BOOJHAWON (Mrs)
for Director of Civil Aviation

Encl.

AS GOPEE ENGINEERS CO LTD
150 St. Beau Bassin
4B, Walter Bessant St.
Tel: 464 4266
47564175 - BRN: C17151358

TARMAC DETAILS : NOTE THAT ALL MATERIALS OF LAYERS TO BE COMPACTED :-

(1) Top Soil (Hardcore fillings) to be compacted

4

11 (a)
(b) (c) (d) (e)

150mm top Layer of Crusher Run to be Compacted
60m³ min Layer Tarmac Grade - - to be Compacted
0/14

1900-1901

- HARDCORE FILLINGS
- 150mm Crusher Run
- TARMAC GRADE

TARMAC DETAILS